



**NOTES**

1. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH NETWORK STANDARD 113 AND DRAWING 184.970.

ITEM	DESCRIPTION	REF DRAWING
10	FAN DAMPER COUNTERWEIGHT	117633-1
9	WALL MOUNTED AWNING PULLEY	117635-1
8	FAN DAMPER CRANK ARM	117633-1
7	FAN DAMPER ASSEMBLY	117633-1
6		
5	EXHAUST FAN DAMPER HOUSING	117633-1
4	SUBSTATION EXHAUST FAN	AS SPECIFIED
3		
2	SUBSTATION EXHAUST FAN MOUNTING PLATE & ACCESS DOOR	42416-1
1	DAMPER RELEASE TRIGGER & RING	117635-1

**CAD DRAWING**  
DO NOT MANUALLY AMEND

**AMENDMENTS**

6. NEW DRAWING MADE. DRAWING RE-TITLED AND ALTERED TO ALIGN WITH NETWORK STANDARDS.  
TOP VIEW OF HORIZONTAL ASSEMBLY ADDED.  
FAN ASSEMBLY ADDED.  
ITEM 9 REPLACED BY ITEM 9.  
ITEM 6 REPLACED BY ITEM 6.  
ITEM 10 ADDED.

22/09/2017  
P. JARVIS  
CHECKED:  
APPROVED:  
D. GREV

08/11/2017  
P. TURRIN  
CHECKED:  
APPROVED:  
D. GREV

7. ITEM 10 RELOCATED TO OTHER END OF HORIZONTAL FAN DAMPER. OPEN POSITION OF VERTICAL FAN DAMPER ADJUSTED.

8. BORDER & TITLEBLOCK UPDATED.

09/09/2024  
M. BENNETT  
CHECKED:  
APPROVED:  
M. BENNETT

**Ausgrid**  
24-28 Campbell Street  
SYDNEY NSW 2000

ISSUED FOR CONSTRUCTION

SCALE	AS SHOWN
DESIGNED	-
DRAWN	CS
CHECKED	RM
APPROVED	JH
DATE	06/1990
TRIM REF	-
PROJECT NUMBER	-

**DISTRIBUTION SUBSTATIONS  
CBD BASEMENT SUBSTATIONS  
FAN ASSEMBLY**

DRAWING No **117632** SHEET 1 AMD 8 SIZE A1