



REFERENCE DRAWINGS	
SUBURBAN SUBSTATIONS	
SUBURBAN SUBSTATIONS WITH E TYPE LV BOARD CABLING & SCHEDULES	178231-1
SUBURBAN SUBSTATIONS WITH E TYPE LV BOARD AC & DC SCHEMATICS	178232-1
WALL MOUNTED TRANSFORMER PROTECTION PANEL	187815-1
WALL MOUNTED CUSTOMER OVERCURRENT PROTECTION PANEL	118558-1
CITY SUBSTATIONS	
CITY BASEMENT SUBSTATIONS WITH E TYPE LV BOARD CABLING	178233-1
CITY CONTROL POINT & UPPER LEVEL SUBSTATIONS WITH E TYPE LV BOARD CABLING	178234-1
CITY SUBSTATIONS WITH E TYPE LV BOARD CABLE SCHEDULE	178235-1
CITY SUBSTATIONS WITH E TYPE LV BOARD AC & DC SCHEMATICS	178236-1
CITY SUBSTATIONS WALL MOUNTED TRANSFORMER PROTECTION PANEL	115148-1
WALL MOUNTED CUSTOMER OVERCURRENT PROTECTION PANEL	118558-1

CAD DRAWING DO NOT MANUALLY AMEND AMENDMENTS 2A CONNECTION WAS 2. 2B CONNECTION WAS 2Z/OC. CUSTOMER SUPPLY ACB 2/COG-1a OR 2/COG-2a PN 208/6/9/2 PWJ - 23.108 CHECKED: PIE APPROVED: PIE 2. CBD TRANSFORMER CONNECTIONS UPDATED TO LATEST MANUFACTURER'S DRAWING. CABLE CORE 1 CONNECTIONS CORRECTED IN SUBURBAN TRANSFORMER. INDIVIDUAL CABLE CONNECTIONS TO PROTECTION PANELS AND SIGNAL MARSHALLING BOX SHOWN. CABLE NUMBERS ADDED. REFERENCE DRAWING LIST REVISED. PN 208/6/9/2 PWJ - 8.5.08.08 CHECKED: DRB APPROVED: PIE 3. WIRE 9x RELOCATED TO ADJACENT TERMINAL ON CBD TRANSFORMER CIRCUIT BREAKER. PN PN 02/2010/11/5/1 P.JARVIS 16.2.11 CHECKED: P.TURRIN APPROVED: P.TURRIN 4. NEW AUSGRID BORDER & LOGO ADDED. RLAALAA 30/09/2013 APPROVED T.LAMPARD 5. NEW UPDATED DRAWING BORDER ADDED. S.MUNRO 19/09/2024 CHKD: M.BENNETT APPR: M.BENNETT	1	2	3	4	5	6	7	8
	1	2	3	4	5	6	7	8
	1	2	3	4	5	6	7	8
	1	2	3	4	5	6	7	8
	1	2	3	4	5	6	7	8

24 Campbell Street SYDNEY NSW 2000 P: 9272 3805 ISSUED FOR CONSTRUCTION	SCALE	NTS	E TYPE LV BOARD MERLIN GERIN MASTERPAC TP AIR CIRCUIT BREAKERS EXTERNAL CONNECTIONS		
	DESIGNED	-			
	DRAWN	P.JARVIS			
	CHECKED	W.BYRNE			
	APPROVED	P.HALLEN			
DATE	06/03/2007	SIZE	DRAWING No	SHEET	AMD
TRIM REF	-	A2	178237	1	5
PROJECT NUMBER	103/59/1/6	C&P - DISTRIBUTION SUBS			

C&P 20180416