



PANEL TERMINAL RAIL LAYOUT CABLING & WIRE JUMPERS

PANEL TERMINAL RAIL LAYOUT CABLING & WIRE JUMPERS

PANEL TERMINAL RAIL LAYOUT CABLING & WIRE JUMPERS

- NOTES:**
- ALL CABLING AND WIRE JUMPING SHOWN IS FOR A 3 TRANSFORMER SUBSTATION WITH 2 CUSTOMER OVERCURRENT PROTECTION PANELS. ONLY REQUIRED CABLING AND WIRE JUMPING IS TO BE INSTALLED. SEE THE SUBSTATION DESIGN INFORMATION PACKAGE AND RELEVANT NETWORK STANDARDS.
 - CABLE NAMING COULD ALTER FOR THE POSSIBLE SUBSTATION CONFIGURATIONS. THIS DRAWING SHOULD BE READ IN CONJUNCTION WITH THE CABLING AND CABLE SCHEDULE DRAWINGS 2273555h01 - 02.
 - ALL PANEL WIRING IS TO BE AS LISTED HERE:
 - DC WIRING IS TO BE 7/0.50, 0.6kV GRADE PVC INSULATED COLOURED GREY.
 - EARTH WIRING IS TO BE 7/0.67, 0.6kV GRADE PVC INSULATED COLOURED GREEN/YELLOW (Y/G).
 - A PHASE CT AND AC WIRING IS TO BE 7/0.67, 0.6kV GRADE PVC INSULATED COLOURED RED (R).
 - B PHASE CT AND AC WIRING IS TO BE 7/0.67, 0.6kV GRADE PVC INSULATED COLOURED WHITE (W).
 - C PHASE CT AND AC WIRING IS TO BE 7/0.67, 0.6kV GRADE PVC INSULATED COLOURED BLUE (B).
 - EARTH CT AND NEUTRAL AC WIRING IS TO BE 7/0.67, 0.6kV GRADE PVC INSULATED COLOURED BLACK (Bk).
 - TERMINALS, FUSES AND RELAY CONNECTIONS ARE TO BE FITTED WITH CAUTION LABELS TO WARN OF THE 415V/240 AC HAZARD. ANY EXPOSED TERMINALS ARE TO BE APPROPRIATELY COVERED.
 - ALL WIRING TO HAVE IDENTIFICATION FERRULES FITTED AT BOTH ENDS OF WIRE ADJACENT TO TERMINALS WHERE POSSIBLE. WIRE IDENTIFICATION CODES TO BE IN ACCORDANCE WITH THIS DRAWING.
 - ALARM AND SIGNAL CABLE SCREENS TO BE ISOLATED AND NOT TO BE TERMINATED IN THIS CABINET. SCREENS ONLY TO BE EARTHED AT SCADA CABINET.

TAGNAME	MPG	CATNO	DESC	REF_DWG
X1, X2, X10	UTILUX	3820	RAIL MOUNTED TERMINAL	1185.47
X6, X7	UTILUX	3820	RAIL MOUNTED TERMINAL	1185.47
X8	UTILUX	H2238	RAIL MOUNTED TERMINAL - ORANGE	-
X50	UTILUX	3822	RAIL MOUNTED TERMINAL	1185.47
X5	WEDMULLER	SAK 2.5	RAIL MOUNTED TERMINAL CAT No. 27966	-
X5	WEDMULLER	SAKR	RAIL MOUNTED ISOLATING TERM CAT No. 41226	-

LEGEND

TITLE	DWG No.
RMICB SUBSTATIONS WITH E TYPE LV BOARD AC SCHEMATIC WITH OPTICAL ARC FLASH DETECTION	2273555h01
RMICB SUBSTATIONS WITH E TYPE LV BOARD TRANSFORMER DC SCHEMATIC WITH OPTICAL ARC FLASH DETECTION	2273555h02
RMICB SUBSTATIONS WITH E TYPE LV BOARD CUSTOMER OVERCURRENT DC SCHEMATIC	2273555h03
RMICB SUBSTATIONS WITH E TYPE LV BOARD SUPPLY CABLE LOOPING AND SCADA SCHEMATIC	2273555h04
RMICB SUBSTATIONS WITH E TYPE LV BOARD WITH OPTICAL ARC FLASH DETECTION FIBRE LOOPING AND GENERAL MOUNTING DETAILS	2273555h05
RMICB SUBSTATIONS WITH E TYPE LV BOARD TX WALL MOUNTED PROTN PANEL WITH OPTICAL AFD STYLE 1 LAYOUT AND LABEL DETAILS DIAGRAM	2273555h01
RMICB SUBSTATIONS WITH E TYPE LV BOARD TRANSFORMER PROTECTION PANEL STYLE 1 WIRING DIAGRAM	2273555h02
RMICB SUBSTATIONS WITH E TYPE LV BOARD TRANSFORMER PROTECTION PANEL STYLE 1 CABLE CONNECTION DIAGRAM	2273555h03
RMICB SUBSTATIONS WITH E TYPE LV BOARD TX WALL MOUNTED PROTN PANEL WITH OPTICAL AFD STYLE 2 LAYOUT AND LABEL DETAILS DIAGRAM	2273555h01
RMICB SUBSTATIONS WITH E TYPE LV BOARD TRANSFORMER PROTECTION PANEL STYLE 2 WIRING DIAGRAM	2273555h02
RMICB SUBSTATIONS WITH E TYPE LV BOARD TRANSFORMER PROTECTION PANEL STYLE 2 CABLE CONNECTION DIAGRAM	2273555h03
RMICB SUBSTATIONS WITH E TYPE LV BOARD CUSTOMER OVERCURRENT WALL MOUNTED PROTN PANEL LAYOUT AND LABEL DETAILS DIAGRAM	2273555h01
RMICB SUBSTATIONS WITH E TYPE LV BOARD CUSTOMER OVERCURRENT WIRING DIAGRAM	2273555h02
RMICB SUBSTATIONS WITH E TYPE LV BOARD OPTICAL ARC FLASH DETECTION INDICATION PANEL SCHEMATIC DRILLING AND WIRING DIAGRAM	2273555h01
RMICB SUBSTATIONS WITH E TYPE LV BOARD AND OPTICAL ARC FLASH DETECTION CABLING DIAGRAM	2273555h02
RMICB SUBSTATIONS WITH E TYPE LV BOARD AND OPTICAL ARC FLASH DETECTION CABLE SCHEDULE	2273555h03
RMICB SUBSTATIONS WITH E TYPE LV BOARD SUBURBAN TYPE SUBSTATION WITH 1500kVA TRANSFORMERS SERVICE BOARD GEN ARRANGEMENT AND WIRING	2273555h01
E TYPE LV BOARD MERLIN GERIN MASTERPAC TP AIR CIRCUIT BREAKERS EXTERNAL CONNECTIONS FOR AFD DIST. SUBSTATIONS	2273555h01
RMICB SUBSTATIONS WITH E TYPE LV BOARD AND OPTICAL ARC FLASH DETECTION SCADA PANEL WIRING AND CABLING DETAILS	2273555h01
E TYPE LV BOARD ACCEPTABLE COMBINATIONS	178227
EPOXY RESIN ENCASED PROTECTION CURRENT TRANSFORMER OUTLINE AND DETAILS	125190

REFERENCE DRAWINGS

CAD DRAWING
 1. SEE REVISIONS COLUMN FOR CHANGES.
 2. ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED ARE IN MILLIMETERS.
 3. DIMENSIONS TO FACE UNLESS OTHERWISE SPECIFIED.
 4. DIMENSIONS TO CENTRE UNLESS OTHERWISE SPECIFIED.
 5. DIMENSIONS TO SURFACE UNLESS OTHERWISE SPECIFIED.
 6. DIMENSIONS TO EDGE UNLESS OTHERWISE SPECIFIED.
 7. DIMENSIONS TO CORNER UNLESS OTHERWISE SPECIFIED.
 8. DIMENSIONS TO POINT UNLESS OTHERWISE SPECIFIED.
 9. DIMENSIONS TO AXIS UNLESS OTHERWISE SPECIFIED.
 10. DIMENSIONS TO CENTERLINE UNLESS OTHERWISE SPECIFIED.
 11. DIMENSIONS TO SURFACE UNLESS OTHERWISE SPECIFIED.
 12. DIMENSIONS TO EDGE UNLESS OTHERWISE SPECIFIED.
 13. DIMENSIONS TO CORNER UNLESS OTHERWISE SPECIFIED.
 14. DIMENSIONS TO POINT UNLESS OTHERWISE SPECIFIED.
 15. DIMENSIONS TO AXIS UNLESS OTHERWISE SPECIFIED.
 16. DIMENSIONS TO CENTERLINE UNLESS OTHERWISE SPECIFIED.

Ausgrid
 24 Campbell Street
 SYDNEY NSW 2000
 P: 9272 3805

SCALE: AS SHOWN
 DESIGNED: -
 DRAWN: L.MARTINUZZI
 CHECKED: W.BYRNE
 APPROVED: M.BENNETT
 DATE: 15/06/2012
 TRIM REF: -
 PROJ/ECT NUMBER: SM 6717-1-2
 DRAWING No: 227351 SHEET 3 AMD 2 SIZE A0

RMICB SUBSTATIONS WITH E TYPE LV BOARD TRANSFORMER WALL MOUNTED PROTECTION PANEL WITH OPTICAL AFD STYLE 1 CABLING CONNECTION DIAGRAM

ISSUED FOR CONSTRUCTION

C&P - DISTRIBUTION SUBSTATION