



POLE STEP (ITEM 2)
SET OUT
ALL HOLES ARE [C]

PART END VIEW
SCALE 1:20

PLAN VIEW
SHOWING POLE STEPS
SCALE 1:20

POLE STEP DETAIL
SCALE 1:10

FRONT VIEW
SCALE 1:20

REAR VIEW
SCALE 1:20

REFERENCE DRAWING	
TITLE	DRAWING No
POLE TRANSFORMER - 1 PHASE COMPOSITE POLE GENERAL ARRANGEMENT	244227

DESIGNATION	USE	SIZE
A1	EARTH CABLES	φ41
A2	EARTH CABLES	φ44
A3	EARTH CABLES	φ51
B	CROSSARMS & TRANSFORMER MOUNTING	φ22
C	POLE STEPS	φ30

NOTES

- THIS DRAWING IS TO BE READ IN CONJUNCTION WITH NETWORK STANDARDS 122 AND 128.
- THIS DRAWING IS FOR ITEM 1c OF DRAWING 244227 AND SHOWS HOLES WHICH WILL BE DRILLED BY THE POLE MANUFACTURER BEFORE POLE DELIVERY. ALL OTHER HOLES REQUIRED FOR THE INSTALLATION ARE TO BE DRILLED ON SITE IN THE LOCATIONS SHOWN ON DRAWING 244228.
- REFER TO DRAWING 244227 FOR ITEMS NUMBERS SHOWN IN CIRCLES. HOLES SIZES ARE SHOWN IN SQUARES AND ARE TO BE DRILLED AS PER HOLE SIZE TABLE.
- HOLES FOR CROSSARMS AND TRANSFORMER MOUNTING BRACKET ARE TO BE SYMMETRICAL TO AXIS OF POLE. HOLES FOR POLE STEPS ARE TO BE DRILLED AT ANGLES SHOWN ON POLE STEP DETAIL AND PLAN.

CAD DRAWING
DO NOT MANUALLY AMEND
AMENDMENTS

CONSTRUCTION

20110714

<p>ASSET ENGINEERING, POLICY AND STANDARDS TRANSMISSION & DISTRIBUTION SUBSTATION ENGINEERING 24 CAMPBELL STREET, SYDNEY</p>	SCALE	AS SHOWN	<p>STANDARD CONSTRUCTION SINGLE PHASE - 11k/22kV COMPOSITE POLE MOUNTED DISTRIBUTION TRANSFORMER 0-63kVA 14 METRE POLE MANUFACTURER DRILLING</p>
	DESIGNED	P.JARVIS	
	DRAWN	P.JARVIS	
	CHECKED	D.THENUWARA	
APPROVED	D.GRICEV	PROJECT NUMBER	129021840
DATE	8.10.19	PROJTRAK NUMBER	
		SIZE	A1
		DRAWING No	251878
		SHEET	1
		AMD	0