



NOTES :

1. THE FOLLOWING INFORMATION IS OBTAINED FROM THE PROJECT DESIGN DRAWINGS:
 - a. POLE LENGTH AND STRENGTH.
 - b. SPECIAL FOUNDATION REQUIREMENTS.
 - c. POLE EMBEDMENT DEPTH.
 - d. CONDUCTOR SIZE.
 - e. STAY REQUIREMENTS.
 - f. DEVIATION ANGLE.
 - g. ASSESSED EARTHING REQUIREMENTS.
2. THE MAXIMUM LINE DEVIATION ANGLE TO BE CONSTRUCTED ON THIS ARRANGEMENT IS TO BE DETERMINED BY THE LINE DESIGNER.
3. POLE STEPS ARE TO BE INSTALLED IN ACCORDANCE WITH THE REQUIREMENTS OF NS128.
4. IN AREAS WHERE THE 22KV NETWORK CANNOT BE WORKED ON USING LIVE LINE TECHNIQUES, UNDERBUILT CIRCUITS SHALL BE INSTALLED WITH A MINIMUM CLEARANCE OF 1200mm. IN AREAS WHERE THE 22KV NETWORK CAN BE WORKED ON USING LIVE LINE TECHNIQUES, UNDERBUILT CIRCUITS SHALL BE INSTALLED WITH A MINIMUM CLEARANCE OF 2500mm.
5. THE LOAD AND DEVIATION ALLOWABLE ON THE EYEBOLTS IS TO BE DETERMINED FROM DRG: 520324.
6. LONGROD INSULATORS TO BE USED UNDER NORMAL CONDITIONS.
7. POLES SHALL BE DRILLED, SCARFED AND DRESSED ON SITE. DRILLING AND SCARFING TO BE TREATED WITH APPROVED PRESERVATIVES.
8. EYEBOLTS ARE TO BE INSTALLED IN THE DIRECTION OF THE OVERHEAD CONDUCTORS.
9. NON-TENSION COMPRESSION SLEEVES TO BE USED WHEN REQUIRED TO JOIN CONDUCTORS.
10. ALL BOLTS PASSING THROUGH TIMBER ARE TO BE COATED WITH GRAPHITE GREASE.
11. LINE POST INSULATORS ARE TO BE FITTED WHERE LINE DEVIATION IS LESS THAN 90°.
12. REFER TO DESIGNER SAFETY REPORT D21/48636 FOR ATYPICAL HAZARDS ASSOCIATED WITH THIS STANDARD CONSTRUCTION.

ITEM	DESCRIPTION	DRG. No	STOCK CODE	QTY
11	STEP - POLE, SCREW-IN (SEE NOTE 3)	250144	185198	A/R
10	JOINT - NON TENSION, COMPRESSION (TO SUIT CONDUCTOR)	514053		3
9	CLAMP - CONDUCTOR, ASSEMBLY	508781	H12110	3
8	INSULATOR - 22kv POST, CLAMP TOP, MOUNTED ON GAIN BASE BRACKET		178293	3
7	BOLT & NUT - M20, HEX., GALVANISED (LENGTH TO SUIT POLE)	515466		6
6	INSULATOR - 11/22kv LONGROD, STRING ARRANGEMENT AR-2	565715		6
5	WASHER - FLAT, M20, GALVANISED	518081	177986	12
4	WASHER - CONICAL, M20, GALVANISED	518082	H39655	12
3	WASHER - SQUARE, 75x75x6mm, GALVANISED (Ø22mm HOLE)	518081	H39231	24
2	EYEBOLT - M20, GALVANISED (LENGTH TO SUIT POLE) (SEE NOTES 5 & 8)	513653		6
1	POLE - TIMBER (AS REQUIRED)	513988		1

ALL DIMENSIONS IN MILLIMETRES UNLESS NOTED OTHERWISE. DO NOT SCALE.

CAD DRAWING DO NOT MANUALLY AMEND A M E N D M E N T S	DWN: PATRICIA RIOS	APPD by: GLENN FORD
	CHKD: PHILLIP JONES	DWN: PATRICIA RIOS
DATE: 14/01/2020 NOTES AMENDED MATERIAL LIST UPDATED.	APPD by: GLENN FORD	
1	DATE: 18/02/2021 NOTES AMENDED MATERIAL LIST UPDATED.	
2	APPD by: GLENN FORD	

NETWORK STANDARD

145 NEWCASTLE RD WALLSEND,
NSW 2287

SCALE	1:25	STANDARD CONSTRUCTION			
DESIGNED	PHIL JONES	22kv VERTICAL TERMINATION			
DRAWN	PATRICIA RIOS	CONSTRUCTION			
CHECKED	PHIL JONES	3-140			
APPROVED	STEPHEN CONNOR				
DATE	12/09/07				
PROJECT NUMBER	STD				
PROJTRAK NUMBER	-	SIZE	DRAWING No	SHEET	AMD
		A3	184959	01	2