

1 2 3 4

A



B

STOCKCODE 71233

C

NOTES

1. REFER TO NS130 FOR INSTALLATION DETAILS.
2. STRIP TO CONFORM TO A.S. 2648 PART 1.
3. LETTERING IS TO BE BLACK 35mm HIGH ON ORANGE POLYTHENE STRIP. MINIMUM THICKNESS OF STRIP TO BE 0.20mm.

CONSTRUCTION

D

|   |  |          |     |   |             |       |   |
|---|--|----------|-----|---|-------------|-------|---|
| CAD DRAWING<br>DO NOT MANUALLY AMEND<br>AMENDMENTS<br>5. NEW BORDER ADDED<br>STOCKCODE ADDED<br>EA CHANGED TO AUSGRID<br>NOTES AMENDED<br>P/N: PM01-00209-1-3-2<br>DATE: 30-05-2012<br>DRAWN: C.MABBUTT<br>CHECKED: B.WEBSTER<br>APPROVED: P.JARVIS | DISTRIBUTION OPERATIONS & RELIABILITY<br>LOGISTICS & DISTRIBUTION ENGINEERING<br>25-27 POMEROY STREET, HOME BUSH | SCALE    | 1:5 | CABLE INSTALLATIONS<br>POLYTHENE WARNING STRIP<br>DETAILS | PROJECT No. |       |   |
|   |  | DESIGNED |     |   | PRJTRK No.  |       |   |
|   |  | DRAWN    |     |   | Sheet       | 1     |   |
|   |  | CHECKED  |     |   | A4          | 49070 | 5 |
|   |  | APPROVED |     |   |             |       |   |
| DATE  | 21/06/2000   |          |     |   |             |       |   |

