



NS 171 DETAIL - APPENDIX B




TYPE A




TYPE B

M10 MECHANICAL ANCHORS  
AT 300mm CTS.  
EMBED 50mm INTO SLAB.



TYPE C

TO BE READ IN CONJUNCTION  
WITH DRAWING No. 208655

|   |  |          |             |  |             |        |   |
|---|--|----------|-------------|--|-------------|--------|---|
| CAD DRAWING<br>DO NOT MANUALLY AMEND<br>AMENDMENTS<br>0. ISSUED FOR<br>CONSTRUCTION<br>JA 27-05-2010<br>1. NEW AUSGRID<br>BORDER & LOGO<br>ADDED.<br>R.LAALAA 17.10.13<br>APPROVED T.L. |  NETWORK STANDARD<br><b>Ausgrid</b> | SCALE    | 1:10        | CABLE SLOT SEAL<br>ALTERNATIVE CONFIGURATIONS<br>USED FOR CABLE OPENINGS<br>THROUGH FLOOR SLABS. | PROJECT No. |        |   |
|   |  | DESIGNED |             |  | PRJTRK No.  |        |   |
|   |  | DRAWN    | JA          |  | Sheet       | 1      |   |
|   |  | CHECKED  | JW          |  | A4          | 208657 | 1 |
|   |  | APPROVED | M-DESIGN JW |  |             |        |   |
| DATE  | MARCH 2009   |          |             |  |             |        |   |