




HOLE SIZES		USE	SIZE
A1	EARTH CABLES		ø41
A2	EARTH CABLES		ø41
A3	EARTH CABLES		ø51
B1	INTELLIPIPER MOUNTING		ø22
B2	INTELLIPIPER MOUNTING (12mm COACH SCREW)		PILDT HOLE
C1	AIR BREAK SWITCH MOUNTING		ø22
C2	AIR BREAK SWITCH OPERATING MECHANISM MOUNTING		ø22
C3	AIR BREAK SWITCH DOWNPOD SUPPORT (12mm COACH SCREW)		PILDT HOLE
D1	HY CROSSARM		ø22
D2	LV ABC BRACKET		ø22
E	12mm COACH SCREW		PILDT HOLE
F	M12 SELF-DRILLING SCREW		PILDT HOLE
G	1/4" EYE BOLT		PILDT HOLE
H	POLE STEP		ø30

STANDARD CONSTRUCTION
11kV S&C INTELLIRUPTER PULSECLOSER
MOUNTED ON A COMPOSITE POLE
WITH BY-PASS AIR BREAK SWITCH
POLE DRILLING DETAILS

SIZE B1	DRAWING No 244231	SHEET 02	AMD 0
------------	----------------------	-------------	----------