



SUMMARY OF MASS:-

TRANSFORMER OIL VOL.	623	Ltrs.
TRANSFORMER TOTAL	2155	kg.
ENCLOSURE	100	kg.
CHANNEL BASE	100	kg.
L.V. SWITCHGEAR	250	kg.
H.V. SWITCHGEAR	350	kg.
KIOSK TOTAL	2955	kg.
CONCRETE BASE	2000	kg.
TOTAL MASS	4955	kg.

PAINT
 TRANSFORMER - STORM GREY N42
 ENCLOSURE - RAIN FOREST GREEN G15

1	36	VALVE BALL 32MM BORE LOCKABLE	VAL5081
1	35	T/C, ROTARY 33KV,9POS,60A, GAMEX	TCR060A9P3PH
1	34	BATTERY BOX	SCHNEIDER-BATTBOX
1	33	BATTERY MOUNTING PLATE ASSEMBLY	S1B2372701
1	32	EARTH BAR LINK	S1B2305101
1	31	EARTH BAR LINK	S1B2305001
1	30	MAIN EARTH BAR	S1B2304901
1	29	FINAL ASSEMBLY OF CHANNEL BASE	S1B2068301
1	28	ENCLOSURE WALL	S1A9972901
1	27	DMA RM6 11KV 25KA/3S MOT P.SW	RM62N61XIQIEAMT101
1	26	POWERSENSE BOX	POWERSENSE
1	25	PLUG,GAL,FLG,DN32,M	PLG1362
1	24	HD SP BACK ENTRY PLUG 10A WHI	PDL905WH
1	23	LABEL - HIGH VOLTAGE	LAB5279
1	22	ENCL ASSY FIBREGLASS FOR L RANGE	KEAKLENC-BOL-V4
1	21	OIL PRESENCE INDICATOR	IND5026
1	20	SAIF LV BOARD KL #ZEA102 LB 4/4/4/4	EZEA102
3	19	SURGE ARRESTOR AK POWER SOLUTIONS 5KA	BSH5122
4	18	BSH ASSY #73 3.3kv 1000A	BSH3905
3	17	BUSH WELL 33KV, 200 A, TO SUIT ELAST. K1501-A1	BSH2023
3	16	INSERT 22KV,200A, ELASTIMOLD K1501-A1	BSH1664
1	15	PRESSURE SWITCH COVER	BBV1737001_MIG26
1	14	UNISTRUT FOR HV CABLE SUPPORT	BAU1560201
2	13	WARNING LABEL - RM6	BAU1559301
1	12	BAFFLE BOTTOM HV	BAU1521901
1	11	RM6 RAISING PLINTH ASSLY - LH	BAU1513301
1	10	RM6 RAISING PLINTH ASSLY - RH	BAU1513201
1	9	TERMINAL BOX - ASSLY	BAU1202701
1	8	PRESSURE SWITCH LABEL	AAV8357101_MIG26
1	7	PRESSURE SWITCH DISPLAY	AAV7454701_MIG26
1	6	RM6 SWITCHGEAR EXTENSION HANDLE	A048069
1	5	CONCRETE BASE	6675359C
1	4	TANK FINISH AUSGRID KL 600KVA	5505152801
1	3	NAME PLATE 600KVA 11/0.433kV Dyn1 +3 to -5 in 1.5% STEPS	4943264301
1	2	MASS PLATE KL 600 KVA	4942191601
2	1	SIGN DANGER-HIGH VOLT KEEP OUT	4942122-9

REFERENCE DRAWING LIST

DESCRIPTION	DRAWING NUMBER
RM6 GA WITH WIRING DIAGRAM	S1B2134500
POWERSENSE	S1B2135000

REV	DATE	DETAILS OF REVISION	DRAWN	CHKD	APPR
05	23/10/15	ECN 1440: Issued for construction. LV board view updated.	MJ	AS	TAS
04	05/09/15	ECN 1427: LV copper flexibles modified to 2 point connection on Bushing palm	MJ	AS	TAS
03	08-01-15	DETAIL "B" ADDED, REFER SHEET 2/2. UPDATED DRG. ON CUSTOMER FEEDBACK. ECN# 1283	DS	AS	TAS
02	13-11-14	MASS PLATE ADDED AT TX. LEVEL.	DS	MJ	TAS
01	23-10-13	DRAIN VALVE SIZE CHANGED TO 32MM	AA	SH	GA
00	10-10-13	RELEASED FOR MANUFACTURING	AA	SH	GA

Scale: 0.075
 Tolerancing Standard: ISO 2768cL
 ISO 8015
 Units of measure: millimeter

Schneider Electric

AUSGRID KL GENERIC GA FOR 600 KVA
 CONTRACT # AG2869/11, ITEM # 10, 11, 12 & 13

Number: **EAV4695802**
 Revision: **05**
 Sheet: **1/2**

The information is highly confidential and is the exclusive property of Schneider Electric Group. Copyright reserved. This drawing must not be used for any purpose other than that expressly permitted in writing by the owners and must not be disclosed or reproduced in any way without permission from the owners in writing. This drawing must be returned to the owners when the purpose has ceased.

242584_01r00